



liftinstituut
SINCE 1933



EU-TYPE EXAMINATION CERTIFICATE

Issued by Liftinstituut B.V.
identification number Notified Body 0400,
commissioned by Decree no. 2018-0000125182

Certificate no. : NL12-400-1002-061-10 Revision no.: 3

Description of the product : Door locking device with hook for horizontal power operated sliding doors. Both central and side opening

Trademark : Merih

Type no. : KLT 004

Name and address of the manufacturer : Merih Asansör Sanayi ve Ticaret A.Ş.
Başkent OSB, Recep Tayyip Erdoğan Bulvarı, No:8, Temelli Sincan, Ankara, Türkiye

Name and address of the certificate holder : Merih Asansör Sanayi ve Ticaret A.Ş.
Başkent OSB, Recep Tayyip Erdoğan Bulvarı, No:8, Temelli Sincan, Ankara, Türkiye

Certificate issued on the following requirements : Lifts Directive 2014/33/EU

Certificate based on the following standard : EN81-1/2:1998+A3:2009, EN81-20:2020, EN81-50:2020

Test laboratory : None

Date and number of the laboratory report : None

Date of EU-type examination : April - July - December 2012, April – October 2016, December 2021

Additional document with this certificate : Report belonging to the EU- type examination certificate no.: NL12-400-1002-061-10 rev.3

Additional remarks : This revision replaces certificate NL12-400-1002-061-10 rev. 2 of 18-11-2016
Max. rated voltage 230 VAC
Max. rated current 0,5A/1,0A
Max. door height 2300 mm
Door width 700 - 1300 mm
Furthermore see chapter 5 of the report belonging to this EU type examination certificate.

Conclusion : The safety component meets the requirements of the Lifts Directive 2014/33/EU taking into account any additional remarks mentioned above.

Amsterdam

Date : 10-12-2021
Valid until : 10-12-2026

ing A.J. van Ommen
International Business
Manager

Certification decision by